



8' ground rod, clamp and #6 bare copper ground wire
 (Supplied and installed by consumer)
 Grounding conductor shall be connected from the ground
 lug in meter base to the ground rod(s)
 Cooperative requires the meter base to be grounded

Consumer to provide all materials on the service pole, including the service pole.
 CVEC to provide the meter base (200 Amp or larger) and meter.
 Meter base can be mounted on either side of the service pole.
 When a service drop to a service pole is greater than 10 ft. the consumer must install
 a round 20 ft. service pole

**PERMANENT OVERHEAD SERVICE FROM
 CVEC POLE TO A 20' ROUND SVC POLE
 EXCEEDING 10 FT.
 (400 AMP MAX)**



CENTRAL VIRGINIA
 ELECTRIC COOPERATIVE

11/27/2012