



Cooperative to install cable from pad mounted Transformer to meter base  
 Consumer to provide a ditch per Cooperative's specifications

When conduit is required, consumer to provide pull rope.

3" Conduit  
 (Cooperative will install)

8' ground rod, clamp and #6 bare copper ground wire  
 (Supplied and installed by consumer)  
 Grounding conductor shall be connected from the ground  
 lug in meter base to the ground rod(s)  
 Cooperative requires the meter base to be grounded

**UNDERGROUND PERMANENT SERVICE TO  
 STRUCTURE- Max 400 Amp**



**CENTRAL VIRGINIA  
 ELECTRIC COOPERATIVE**

**11/07/2012**